



Office of the Chief Fire Officer, Bengaluru-East Zone,
Karnataka Fire & Emergency Services,
Commissariat Road, Bengaluru-560 025.



No. 1355/CFO/Bng-East/FSR/2021

Dated: 29-11-2021.

ANNEXURE - 1

Group - B Educational Building

NBC-2016, Part-4, Table 7(11) 3.1.3 Group B Educational Buildings Sub Division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC-2016 are mandatory).

To,
The Authorised Signatory
M/s. Saraswathi Vidya Mandira Trust,
Site No. 50 to 70, Maruthi Layout,
Anekal Town, Bangalore.

Sir,

Sub : Issue of "**Fire safety recommendation**" with respect of fire prevention, fire fighting and evacuation measures required at "M/s. Saraswathi Vidya Mandira, Site No. 50 to 70, Maruthi Layout, Anekal Town, Bangalore" - reg.

Ref : 1) Your request letter dated: 21-11-2021.
2) Inspection report No: 147/DFO/E-city/Bng/FSR/2021 Date: 26-11-2021.

<<<<>>

With reference to the subject cited above, the premises of "M/s. Saraswathi Vidya Mandira, Site No. 50 to 70, Maruthi Layout, Anekal Town, Bangalore" was inspected by the District Fire Officer, Sarjapura Fire Station, Bengaluru on 17-11-2021 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

A. Details of the building / premises :-

01	Name and Address of the Applicant.	: The Authorised Signatory M/s. Saraswathi Vidya Mandira Trust, Saraswathi Vidya Mandir, Site No. 50 to 70, Maruthi Layout, Anekal Town, Bangalore.
02	Name and Address of the premises.	: M/s. Saraswathi Vidya Mandir, Site No. 50 to 70, Maruthi Layout, Anekal Town, Bangalore.
03	Name and address of the Building owner	: M/s. Saraswathi Vidya Mandira Trust, Site No. 50 to 70, Maruthi Layout, Anekal Town, Bangalore.



04	Number of buildings	:	One Building.
05	Number of floors	:	Ground + 02 upper floors.
06	Floor-wise details of occupancy:-		
	Ground floor	:	1 Principal room, 1 Secretary room & 15 Class rooms.
	1 st floor	:	16 Class rooms, 1 Computer room, 1 Biology Lab & 1 Staff room.
	2 nd floor	:	10 Class rooms, 1 Staff room & 1 Auditorium.
07	Height of the building	:	11.10 mtrs.
08	Site area	:	3,160.59 Sq.mtrs.
09	Built-up area of each floor:-		
	Ground floor	:	933.78 Sq.mtrs.
	1 st floor	:	933.78 Sq.mtrs.
	2 nd floor	:	933.78 Sq.mtrs.
10.	Total built-up area	:	2,801.34 sq.mtrs.
11.	Surrounding properties:-		
	Front (North)	:	12.00 mtrs wide Main Road.
	Rear (South)	:	Private Vacant land.
	Side (East)	:	Private Vacant land.
	Side (West)	:	10.00 mtrs wide Taluk Office Road.
12.	Set-back area available around the building :-		
	Front (North)	:	Min 1.80 mtrs.
	Rear (South)	:	Min 1.00 mtrs.
	Side (East)	:	Min 2.50 mtrs.
	Side (West)	:	Min 2.10 mtrs.

B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The premises accessible from 12.00 mtrs wide Main Road, located on the Northern side & road are hardened to carry the weight of 45,000 kgs capacity.	Complied.



02.	No. of entrances	One entry cum exit has been provided.	Complied.
03.	Width of entry / exit	One entry cum exit of 6.00 mtrs width from has been provided.	Complied.
04.	Diesel generators.	One no. DG of 15 KVA capacities has been provided and connected to all the emergency provisions of the building.	Complied.
05.	No. of staircases available	Nos. of staircases : 01	Complied.
		Width of staircases : 1.30 mtrs	
		Width of treads : 30cm	
		Height of risers : 15cm	
		Nos. of riser per flight : 11 no.s	
		Height of handrails : 1.00m	
		Head room clearance : 3.20 m	
06.	Fire extinguisher	25 no.s ABC type extinguishers, each of 6 kgs capacity, 5 no.s ABC type extinguishers, each of 4 kgs capacity, & 03 no.s CO ₂ extinguishes, each of 4.5 kgs capacity have been provided.	Complied.
07.	First aid Hose reel hose.	6 Nos. Hose reel hoses have been provided near the staircase. The hose reel hose of 19mm size and of adequate length to reach farthest point of the floor with shut off branch having nozzle of 5mm size at stair case of the every floor.	Complied.
08.	Terrace tank over respective tower terrace.	One terrace tank of 10,000 ltrs water capacity have been provided.	Complied.
09.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Booster pump capable of delivering 450 LPM has been provided.	Complied.
10.	Fire control room at ground floor.	The fire control room Provided at ground floor & All emergency numbers displayed.	Complied.
11.	Escape routes	Directions in which the Teachers/Staff/Students have to move in the event of any emergency have been indicated in the corridor of the building as a guide during evacuation. This marking are written in luminous	Complied.



		paint.	
12.	Fire order	A notice board indicating with the details of action taken by the Teachers/Staff/Students in case of an emergency/fire has been displayed in prominent place.	Complied.
13.	No smoking board.	Displayed.	Complied.
14.	Fire fighting training	Not Trained.	40% of the staffs/Teachers shall be got trained in fire prevention, fire fighting & evacuation at R.A.Mundkur fire & emergency service Academy, Bannerghatta road, Bangalore-560 029.
12.	<u>Fire precautionary measures :-</u> <ul style="list-style-type: none"> A) Explosive and flammable materials should not be stores in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B) Accumulation of combustibile waste in and the premises should be avoided. C) The exit ways shall be always kept clear without any obstruction. D) Liquefied petroleum gas should not be stores in the building. E) The doors shall not be kept locked / latched during working hours and shall be free from obstruction. F) During the class hours the class room doors shall not be locked from inside to out side. G) As per Honorable Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year be conducting Fire Safety drills with co-ordinate Fire Service department. 		

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing Fire Safety Recommendation to "M/s. Saraswathi Vidya Mandira, Site No. 50 to 70, Maruthi Layout, Anekal Town, Bangalore" subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 3 months and compliance from the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable.

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.

Copy to the District Fire Officer,
E-city Fire Station, Bengaluru.



Yours faithfully,

[Signature]
Chief Fire Officer
Bengaluru East Zone
Bengaluru



Office of the Chief Fire Officer
Bengaluru-East Zone
Karnataka Fire & Emergency Services
No. 04, Commissariat Road, Bengaluru-560 025.



No. 1355/CFO/Bng-East/FSCR/2021

Dated: 29-11-2021.

"Annexure-2"

To,
The Authorised Signatory
M/s. Saraswathi Vidya Mandira,
Site No. 50 to 70, Maruthi Layout,
Anekal Town, Bangalore.

Sir,

Sub : Issue of "Fire Safety Compliance report" with respect to fire prevention, fighting and evacuation measures maintained at "M/s. Saraswathi Vidya Mandira, Site No. 50 to 70, Maruthi Layout, Anekal Town, Bangalore" - reg.

Ref : 1) This office FSR No.1355/CFO/Bng-East/FSR/2021 Date: 29-11-2021.
2) Your request letter dated: 21-11-2021.
3) Inspection report no: 147/DFO/E-city/Bng/FSR/2021 Date: 26-11-2021.

<<<>>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises at "M/s. Saraswathi Vidya Mandira, Site No. 50 to 70, Maruthi Layout, Anekal Town, Bangalore" with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, the management of "M/s. Saraswathi Vidya Mandira" had requested for the compliance report from our department. In this regard the District Fire Officer, Mahadevapura Fire Station, Bangalore was re-inspected on 26-11-2021 and submitted the report to issue Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to at "M/s. Saraswathi Vidya Mandira, Site No. 50 to 70, Maruthi Layout, Anekal Town, Bangalore" subject to proper maintenance of fire fighting installations in the good working conditions. "This report is valid for only one year from the date of issue and is renewable without fail".

Copy to: The District Fire Officer,
E-city Fire Station, Bengaluru.



Yours faithfully,


Chief Fire Officer
Bengaluru East Zone
Bengaluru



ಛಾಲ್ಟಿ ಅವಧಿ Challan Validity	ಜಿಲ್ಲೆ District	ಇಲಾಖೆ Department	ಡಿಡಿಓ ಕಛೇರಿ DDO Office	
7 Days	BENGALURU URBAN	DEPARTMENT OF KARNATAKA FIRE & EMERGENCY SERVICES	DIVISION FIRE OFFICE, KARNATAKA FIRE AND EMERGENCY SERVICES, BANGALORE EAST ZONE, BANGALORE	
ವರ್ಗ Category	ದಿನಾಂಕ Date	ಚಲನ್ ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ Challan Reference Number	ಡಿಡಿಓ ಕೋಡ್ DDO Code	
Government	27/11/2021	CR1121007000572959	140260	
ಹೆಸರು ಹೆಸರು Sender Name	Saraswathi VidyaMandira Truat			
ವಿಳಾಸ Address	Site No.50 to 70, Maruthi Layout, Anekal Town, Bangalore.			
ಉದ್ದೇಶ Purpose	ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ Head of Account	ಉಪ ಉದ್ದೇಶದ ಹೆಸರು Sub Purpose Name	ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ Purpose Specific ID	ಮೊತ್ತ Amount
OTHER ITEMS- FIRE DEPARTMENT	0070~60~109~0~02~000	12.For issue of Advise on Fire Prevention and Fire Fighting for non high rise buildings.	NA-	20000
ಸಂಧಾಯ ಸಂಧಾಯ Finance Bank	STATE BANK OF INDIA	ಒಟ್ಟು ಮೊತ್ತ Grand Total		20000
ಪಾವತಿ ಹಂತ Payment Status	Payment Yet To Be Made At Agency Bank	ಒಟ್ಟು ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ Total Amount in Words		Twenty Thousand Only
ಪಾವತಿ ವಿವರಗಳು\Payment Details				
ಪಾವತಿ ವಿಧ Payment Mode	Cash			

ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಾರ್ವಜನಿಕ ಸೇವೆ
Karnataka Business Branch (40558) Bengaluru-01
P.F.No. 3858774
29 NOV 2021
CASHIER
CHECK#
CHECK#

J-118123814

223

Chief Fire Officer
Bengaluru East Zone
Bengaluru